



Uspešno delovanje stabilnega sistema na linijski vakumerki.



gorenje

<http://www.gorenje.com>

Sodiš e registracije:
Okrožno sodiš e Celje
Reg.št. vložka: 1/00461/00

Nadzorni svet:
Predsednik dr. Jože Zagožen

Gorenje, d.d.

Investicije in Vzdrževanje
3503 Velenje, p.p. 107
Telefon: 03 899 10 00
Faks: 03 899 26 00

Osnovni kapital:
50.909.697,88 EUR

Building: Building at Partizanska cesta 12, 3503 VELENJE

CONFIRMATION ABOUT THE SUCCESSFUL FIRE EXTINGUISHING WITH STABLE (FIX) SYSTEM BONPET ON THE SPECIAL DEVICE (MACHINE) FOR PLASTIC PARTS

The event: Fire on the DEVICE (machine) for plastic parts. The event date: 18.08.2007

Description of the operation:

The BONPET (stable) fix fire extinguishing system is installed on the special device (machine) for plastic parts and during it's operation the overheating of the device occurred. Because of the overheating the PVC plate (which is reproductive material) started to burn which consecutively activated the BONPET fix system.

This event happened on 18.08.2007 at 1:38 am. The device was operational again in two hours, because of the BONPET fix system was activated on time there was no damaged caused to the device (machine).

The company BONPET SYSTEMS was notified about the activation at 7.00 AM the same day and at 10:00 AM on the same day the BONPET fix system was operational.

Enclosed:

Photo
minutes

CONFIRMED BY:

g. Peter KOBAL

Velenje 19.09.2007


