



Uspešno pogašen požar v transformatorski celici razdelilnih postaj, dne 21.12.2006



Stanje pred požarom



Energetika

Petrol Energetika, proizvodnja in distribucija energetskih medijev, d.o.o. Koroška cesta 14, SI-2390 Ravne na Koroškem, Telefon: 02 870 6100, Fax: 02 870 6106

Company: PETROL ENERGETIKA d.o.o.

Building: Building at Koroška cesta 14, 2390 Ravne na Koroškem

CONFIRMATION ABOUT THE SUCCESSFUL FIRE EXTINGUISHING WITH FIRE EXTINGUISHER BONPET

The event: The fire in power transformer cell station. The event date: 21.12.2006

Description of the operation:

The fire was successfully extinguished with the activation of the Automatic fire extinguisher ampoule BONPET. The fire damage was reduced (as the consequence of the effective extinguishing) to the minimum. There were also no consequences on activity of the power transformer cell. Only one contact was damaged as could be also seen from the photos.

We estimate, also on the base of previous experiences with that kind of fires, that with the quick and effective fire extinguishing, the damage in amount from 40.000,00 € to 60.000,00 € was prevented. Considered cost of loss of activity is not on assessment.

Enclosed:

- photo

PETROL Energetika, d.o.o. Koroška cesta 14 2390 Ravne na Koroškem

CONFIRMED BY:

[Handwritten signature]

Petrol Energetika, d. o. o., Sklep številka: Srg 93/00255, Vpis v sodni register 12. 2. 1993 na Okrožnem sodišču/Slovenj Gradec. Številka registrskega vložka: 1/07659/00, osnovni kapital: 1.069.480.000 SIT, matična številka: 5705754, identifikacijska številka: SI56859708, TRR: 02923-0255139434 pri NLB d.d., Ljubljana